

CERTIFICATE OF CONFORMITY

Certificate Number:	QAD-2025.0586.01-LV	رقم الشهادة:
This certificate is issued for the product:	LV Switchgear and LV PFCB Assembly	تم منح هذه الشهادة للمنتج:
Manufactured by:	GAMA ENGINEERING FZC E3-12, SAIF Zone, P.O. Box 8886, Sharjah, UAE	تم التصنيع بواسطة:
Certificate Holder:	GAMA ENGINEERING FZC E3-12, SAIF Zone, P.O. Box 8886, Sharjah, UAE	الخاص بشركة:
According to Certification Scheme requirement:	Low Voltage Switchgear Conformity Scheme	وفقا لمتطلبات برنامج المطابقة:
Trademark / Brand Name:	Schneider Electric (LVSG)/ EPCOS (PFCB)	العلامة التجارية / الاسم التجاري:

Abu Dhabi Quality and Conformity Council hereby attests the above product(s) have been assessed in accordance with the relevant requirements mentioned above.

يشهد مجلس أبوظبي للجودة والمطابقة على أن المنتج (المنتجات) أعلاه قد تم تقييمه وفقاً للمتطلبات المذكورة في هذه الشهادة

Issued Date:	24 October 2025	تاريخ الإصدار:
Expiry Date:	23 October 2026	تاريخ انتهاء الصلاحية:



Bader Al Shemili

QAD-2025.0586.01-LV

Executive Director of Conformity and Standards Services Sector

- The attached Schedule of Certification bearing the same Certificate Number forms an integral part of this Certificate.
 - This is an electronic certificate and does not require stamp.
 - Visit our website to verify this certificate: <https://jawdah.qcc.abudhabi.ae/en/pages/verify.aspx>
 - Any changes or modification on this certificate will affect its validity.
- بيان المطابقة المشمول بالشهادة والذي يحمل نفس رقم الشهادة يشكل جزءاً لا يتجزأ من هذه الشهادة.
 - تم إصدار هذه الشهادة إلكترونياً ولا تحتاج إلى ختم.
 - للتأكد من صحة هذه الشهادة يرجى زيارة موقع المجلس الإلكتروني: <https://jawdah.qcc.abudhabi.ae/en/Pages/verify.aspx>
 - أي كشط أو تغيير في هذه الشهادة يلغيها.

Schedule of Certification

Certificate Number: QAD-2025.0586.01-LV رقم الشهادة:
 Issued Date: 24 October 2025 تاريخ الإصدار:
 Expiry Date: 23 October 2026 تاريخ انتهاء الصلاحية:

No.	رقم الموديل Model Number	صفات Characteristics	معلومات إضافية Additional information
1	GAMA 250A LV SWITCHBOARD	Maximum current rating: 250A; Rated voltage: 415V/690V/8kV (Ue/Ui/Uimp); Rated short-circuit current: 36kA-1s; Rated frequency: 50/60 Hz; IP rating: IP 42 (Form 2b); Main Busbar size (mm): 1x20x10	UL TEC-01063 / 23-Jun-2021
2	GAMA 400A LV SWITCHBOARD	Maximum current rating: 400A; Rated voltage: 415V/690V/8kV (Ue/Ui/Uimp); Rated short-circuit current: 36kA-1s; Rated frequency: 50/60 Hz; IP rating: IP 42 (Form 2b); Main Busbar size (mm): 1x30x10	UL TEC-01066 / 23-Jun-2021
3	GAMA LV SWITCHBOARD 800A	Rated voltage: 415V/800V/8kV (Ue/Ui/Uimp); Maximum current rating: 800A; Rated short-circuit current: 50kA-1s; Rated frequency: 50/60 Hz; IP rating: IP 54 Form 2b; Main Busbar size (mm): 1x50x10	ASEFA TR N° SPEC22AA5499 / 01-Dec-2022
4	GAMA LV SWITCHBOARD 1600A	Rated voltage: 415V/1000V/12kV (Ue/Ui/Uimp); Maximum current rating: 1600A; Rated short-circuit current: 50kA-3s / 85kA-1s; Rated frequency: 50/60 Hz; IP rating: IP 54; Main Busbar size (mm): 2x60x10	ASEFA TR N° SPEC22AA5500 / 01-Dec-2022
5	GAMA LV SWITCHBOARD 2500A	Rated voltage: 415V/1000V/12kV (Ue/Ui/Uimp); Maximum current rating: 2500A; Rated short-circuit current: 50kA-3s / 85kA-1s; Rated frequency: 50/60 Hz; IP rating: IP 54; Main Busbar size (mm): 2x100x10	ASEFA TR N° SPEC22AA5501 / 01-Dec-2022
6	GAMA LV SWITCHBOARD 4000A	Rated voltage: 415V/1000V/12kV (Ue/Ui/Uimp); Maximum current rating: 4000A; Rated short-circuit current: 57kA-3s / 100kA-1s; Rated frequency: 50/60 Hz; IP rating: IP 54; Main Busbar size (mm): 3x120x10	ASEFA TR N° SPEC22AA5502 / 01-Dec-2022
7	GAMA APFC 75kVAR	Rated reactive power: 75kVAR; Rated voltage: 440V/690V/6kV (Un/Ui/Uimp); Maximum current rating: 127.9A; Rated frequency: 50 Hz; IP rating: IP 31 (Form 2b); Main busbar size (mm): 1x30x10	UL TEC-01064 / 23-Jun-2021
8	GAMA APFC 175kVAR	Rated reactive power: 175kVAR; Rated voltage: 440V/690V/6kV (Un/Ui/Uimp); Maximum current rating: 275.56A; Rated frequency: 50 Hz; IP rating: IP 31 (Form 2b); Main busbar size (mm): 2x30x10	UL TEC-01061 / 23-Jun-2021

Schedule of Certification

Certificate Number:	QAD-2025.0586.01-LV	رقم الشهادة:
Issued Date:	24 October 2025	تاريخ الإصدار:
Expiry Date:	23 October 2026	تاريخ انتهاء الصلاحية:

No.	رقم الموديل Model Number	صفات Characteristics	معلومات إضافية Additional information
9	GAMA APFC 375kVAR	Rated reactive power: 375kVAR; Rated voltage: 440V/690V/6kV (Un/Ui/Uimp); Maximum current rating: 590.5A; Rated frequency: 50 Hz; IP rating: IP 31 (Form 2b); Main busbar size (mm):2x30x10	UL TEC-01062 / 23-Jun-2021
10	GAMA APFC 450kVAR	Rated reactive power: 450kVAR; Rated voltage: 440V/690V/6kV (Un/Ui/Uimp); Maximum current rating: 708.6A; Rated frequency: 50 Hz; IP rating: IP 31 (Form 2b); Main busbar size (mm):2x40x10	UL TEC-01065 / 23-Jun-2021
Remarks/ ملاحظات	The approval of the products listed above is subject to the following requirements: 1. The certification approval does not relieve the contractors installing QCC certified products in complying with RSB guidelines and ADDC standards that are applied to the Low Voltage Switchgear and Panel Boards. 2. All the breakers (both incoming and outgoing) shall be restricted to the components used in the test provided by the third party certification body. 3. The QCC Conformity Document shall be submitted for every switchgear assembly at every product delivery and the AD Trustmark shall fixed in all certified products. 4. Any malfunction or repeated faults of the installed switchgear assembly reported to QCC may lead to the cancellation of the QCC Trustmark. 5. It is the responsibility of the manufacturer to comply with any updated IEC Standards by means of additional product testing as required. 6. It is the responsibility of the supplier to keep their customers aware of the special conditions stated in the test reports that restrict the use of the approved materials at different connection environments. 7. Any product modifications shall be submitted to QCC for compliance verification. 8. The QCC Trustmark license holder shall be registered with ADWEA.		